




ALL CONCRETE TO BE MIX NO. 3. ALL REINFORCING STEEL TO CONFORM TO A.S.T.M. 615, GRADE 40

	APPROVED:  CHIEF, CONDUIT DIVISION	CITY OF BALTIMORE DEPARTMENT OF TRANSPORTATION CONDUIT DIVISION  <b>REINFORCING SLAB FOR          SHALLOW ELECTRIC DUCT</b>	ISSUED	REVISED	REVISED
	 DIRECTOR, DEPARTMENT OF TRANSPORTATION		8 / 2010		
	SCALE : NONE		STANDARD NO. BC 824.08  SHEET 1 OF 1		