



NOTES:

CONCRETE INSERTS FOR RECESSED EXTENSIONS  
 TYPE AS APPROVED BY ENGINEER  
 $\frac{5}{8}$ " - 11 N.C. (3" MIN. LENGTH)

CAST 4 INSERTS IN THE OUTSIDE FACE OF  
 WALL AT EACH SIDE KNOCKOUT. SEE DETAIL  
 ABOVE FOR LOCATION OF EACH  $\frac{5}{8}$ " INSERT.

32 -  $\frac{5}{8}$ " INSERTS REQUIRED FOR EACH  
 PRECAST LINE MANHOLE. INSTALL PLASTIC  
 BOLTS OR COVER FOR PROTECTION OF  
 INSERTS PRIOR TO USE.



APPROVED:

*Richard J. Baker*

CHIEF, CONDUIT DIVISION

*Khalil Zane*

DIRECTOR, DEPARTMENT OF TRANSPORTATION

CITY OF BALTIMORE  
 DEPARTMENT OF TRANSPORTATION  
 CONDUIT DIVISION

INSERT DETAILS FOR  
 RECESSED EXTENSION  
 PRECAST MANHOLE

ISSUED	REVISED	REVISED
8 / 2010		
STANDARD NO. BC 826.06		
SCALE : NONE	SHEET 1 OF 1	