



DROP FRONT
IN-LINE OR STAGGERED

NOTE:

1. KNURL BEFORE BENDING, MIN. KNURLING AS SHOWN.
2. STEPS TO BE TYPE 410 STAINLESS STEEL, MILL FINISH.



APPROVED :

 HEAD, BUREAU OF WATER AND WASTEWATER

 DIRECTOR, DEPARTMENT OF PUBLIC WORKS

CITY OF BALTIMORE
 DEPARTMENT OF PUBLIC WORKS
 BUREAU OF WATER AND WASTEWATER

TYPE 1 STEP FOR
 BRICK MANHOLES

ISSUED	REVISED	REVISED
3 / 2008		
STANDARD NO. BC 831.30		
SCALE : NONE		SHEET 1 OF 1